

## EC – DECLARATION OF CONFORMITY

**Name of organisation:** KIWA sk, s.r.o.  
**Address:** Krivánska 5, 949 01 Nitra  
**CRN:** 44 769 512  
**Manufacturer:** KIWA, spol. s r.o., Slovenská republika  
**Address:** Pekárska 11, 917 01 Trnava  
**Establishment:** Jakuba Haška 1, 949 01 Nitra

**Brand:** **KIWA®**  
**Models:** SPD modules **PODA-275 230V and POD275S 230V**  
**Type:** SPD KIWA type3 - Surge Protective Devices KIWA type 3

**Description of goods:**

The surge protection device (SPD) is an electrical equipment for protection of the electrical circuit and installation system. Location nearby protected equipment - type 3

The above designated products have been assessed according to the § 12 Sect. 3 letter. b) Act No. 264/1999 Coll. and they comply with technical requirement of the following statutory decrees:

**Number:** NV118/2016 Coll. for Low Voltage (LVD 2014/35/EU)  
**Title:** Statutory Decree on Technical requirements and Processes of Assessment of Conformity for Electrical Equipment used in Certain Range of Voltage

This Declaration of Conformity is issued under the responsibility of the manufacturer.

**Essential technical Data:**

**PODA-275 230V**  $U_n = 230 \text{ V AC}$ ,  $I_{SN} = 2,5\text{kA (8/20)}$ ,  $U_p \text{ (L-N)} \leq 0,9\text{kV}$ ,  $U_p \text{ (L-PE)} \leq 1,5\text{kV}$ ,  
 $U_p \text{ (N-PE)} \leq 1,2\text{kV}$ ,  $U_{oc} = 3 \text{ kV}$ , IP 20  
**POD-275S 230V**  $U_n = 230 \text{ V AC}$ ,  $I_{SN} = 2,5\text{kA (8/20)}$ ,  $U_p \text{ (L-N)} \leq 0,9\text{kV}$ ,  $U_p \text{ (L-PE)} \leq 1,5\text{kV}$ ,  
 $U_p \text{ (N-PE)} \leq 1,2\text{kV}$ ,  $U_{oc} = 3 \text{ kV}$ , IP 20

Full specifications are listed in the KIWA catalogue

The following technical standards were used at assessment of compliance:

STN EN 60664-1:2004-07 (33 0420)  
STN 34 5615: 1984 + A1: 1986 + Z1:1997  
European Standards: EN 61643-11:2012, VDE 0675-6: 1989  
International Standards: IEC 61643-11:2011  
Authorised person (AP) identification: EVPÚ a.s. – SKTC-101  
Adress: Trenčianska 19  
Nová Dubnica 018 51, Slovenská republika

**Certificate Number:** 00413/101/1/2008  
**Date of issue:** 02.10.2008

Conformity assessment has been executed in accordance with directives of the EP and Council

and the mark **CE** may be used.

Year of CE marking (Low voltage directive): March 2008

**Declared by:**

**Name:** Ing. Daniel Sidun  
**Position:** Executive Director  
**Address:** Nitra

**Date:** 18<sup>th</sup> May 2017

**Signature:**

*Daniel Sidun*  
**KIWA sk, s.r.o.**  
Krivánska 5  
949 01 Nitra